

To: AL DOUSOR INTERNATIONAL CO. LTD.
Jeddah, Kingdom of Saudi Arabia
Director- Technical & Business Development

Date: 15, June 2017
HH-JSTPP-COM-J010

Attn.: Mr. S. A. Nazeer Hussain

Subject: JSTPP-I, Fuel Additive Approval Letter

Dear Sir,

We, HHI are pleased to issue the approval letter to Al Dousor International Co. Ltd., Jeddah, Kingdom of Saudi Arabia, who performed the fuel additive trial test for our Jeddah South Thermal Power Plant Project by applying the Magnesium based Fuel Additive, named Protea M-228 to protect the Boiler from hot and cold end corrossions.

We are satisfied with the performance of Protea M-228 and the technical support by the Al Dousor team.

We found that the fuel additive, Protea M-228 is technically acceptable. We therefore recommended the use of Protea M-228 to the owner of the Project M/s. Saudi Electricity Company for their commercial operation.

Sincerely yours,



Yun-Boong Kim / Project Manager
Jeddah South Thermal Power Plant Project Stage-1
Industrial Plant & Engineering Division
Hyundai Heavy Industries Co., Ltd

